



# (1) EC-TYPE EXAMINATION CERTIFICATE

- (2) Equipment or protective system intended for use in potentially explosive atmospheres Directive 94/9/EC
- (3) EC-Type Examination Certificate Number: KEMA 00ATEX1132 X
- (4) Equipment or protective system: Load Cell Model SHBxR, BSP, CSP-M, CP-M, HPS, SSB, HCB, 9102, RLC, 5103 and 9103
- (5) Manufacturer: Revere Transducers Europe B.V.
- (6) Address: Ramshoorn 7, 4824 AG Breda, The Netherlands
- (7) This equipment or protective system and any acceptable variation thereto is specified in the schedule to this certificate and the documents therein referred to.
- (8) KEMA Quality B.V., notified body number 0344 in accordance with Article 9 of the Council Directive 94/9/EC of 23 March 1994, certifies that this equipment or protective system has been found to comply with the Essential Health and Safety Requirements relating to the design and construction of equipment and protective systems intended for use in potentially explosive atmospheres given in Annex II to the Directive.

The examination and test results are recorded in confidential report no. 2007353.

(9) Compliance with the Essential Health and Safety Requirements has been assured by compliance with:

EN 50014: 1997 EN 50020: 1994 EN 50281-1-1: 1998 EN 50284: 1999

- (10) If the sign "X" is placed after the certificate number, it indicates that the equipment or protective system is subject to special conditions for safe use specified in the schedule to this certificate.
- (11) This EC-Type Examination Certificate relates only to the design, examination and tests of the specified equipment or protective system in accordance to the Directive 94/9/EC. Further requirements of the Directive apply to the manufacturing process and supply of this equipment or protective system. These are not covered by this certificate.
- (12) The marking of the equipment or protective system shall include the following:

 $\langle \varepsilon_x \rangle$ 

II 1 G or II 2 G EEx ia IIC T6... T4 or EEx ib IIC T6 ... T4



II 2 D T 70 °C

Arnhem, 7 December 2001 KEMA Quality B.V.

T. Pijpker Certification Manager



This Certificate may only be reproduced in its entirety and without any change



(13)

# SCHEDULE

(14)

to EC-Type Examination Certificate KEMA 00ATEX1132 X

## (15) Description

The Load Cells Model SHBxR-C.-..-.EEx(i), Model BSP-...-.EEx(i), Model CSP-M-...-..-EEx(i), Model CP-M-...-.-EEx(i), Model HPS-...-.EEx(i), Model SSB-...-.-EEx(i), Model HCB-C.-..-EEx(i), Model 9102-C.-..-EEx(i), Model RLC-..., Model 5103-... and Model 9103-... are used to convert a mechanical force or load into an electrical signal. The Load Cells are of a hermetically sealed or sealed construction and are provided with a permanently connected cable with a maximum length of 25 m.

The enclosure of the Load Cell provides, depending on the Model, an ingress protection of IP 66, IP 67 or IP 68 in accordance with EN 60529.

Ambient temperature range -20 °C ... +40 °C.

The maximum surface temperature of the enclosure T = 70 °C is referred to a maximum ambient temperature of 40 °C.

#### Electrical data

Model HCB and Model 9102	
Excitation circuit(green and black wires)	in type of explosion protection intrinsic safety EEx ia IIC.
Signal output circuit(white and red wires)	in type of explosion protection intrinsic safety EEx ia IIC.
Sense output circuit (optional) (yellow and blue wires)	in type of explosion protection intrinsic safety EEx ia IIC.

The excitation circuit, the signal output circuit and the optional sense output circuit are galvanically connected and may only be connected to certified intrinsically safe circuits. Voltage, current and power addition of the circuits must be taken into account.

The total maximum values for the above mentioned circuits are:

U	=	19,1	V	
1,	=	323	mA	
P	=	1,25	W	for temperature class T6
		2.75	W	for temperature class T4

The effective internal capacitance  $C_i = 0.4 \text{ nF}$ , the effective internal inductance  $L_i$  is negligibly small.

For longer cables than specified in the description, the capacitance and inductance of the additional cable must be taken into account.



# (13) SCHEDULE

# (14) to EC-Type Examination Certificate KEMA 00ATEX1132 X

## Electrical data (continued)

Model SHBxR, Model BSP, Model CSP-M, Model CP-M, Model HPS, Model SSB, Model RLC, Model 5103 and Model 9103

Excitation circuit(green and black wires)	in type of explosion protection intrinsic safety EEx ib IIC.
Signal output circuit(white and red wires)	in type of explosion protection intrinsic safety EEx ib IIC.
Sense output circuit (optional) (yellow and blue wires)	in type of explosion protection intrinsic safety EEx ib IIC.

The excitation circuit, the signal output circuit and the optional sense output circuit are galvanically connected and may only be connected to certified intrinsically safe circuits. Voltage, current and power addition of the circuits must be taken into account.

The total maximum values for the above mentioned circuits are with exception of the circuits of Model RLC, for loads of 60 kg, 130 kg, 28 t and 60 t:

The effective internal capacitance  $C_i = 0.4 \text{ nF}$ , the effective internal inductance  $L_i$  is negligibly small.

For Model RLC, for loads of 60 kg, 130 kg, 28 t and 60 t, the maximum values for the above mentioned circuits are:

The effective internal capacitance  $C_i = 2,5$  nF, the effective internal inductance  $L_i$  is negligibly small.

For longer cables than specified in the description, the capacitance and inductance of the additional cable must be taken into account.

For use in a potentially explosive atmosphere caused by combustible dust, the Load Cell may also be used without connection to certified intrinsically safe circuits. The electrical data are:

Maximum excitation voltage: 15 ... 30 Vdc (depending on model) Bridge impedance: 350 ... 1450  $\Omega$  (depending on model)



(13)

# **SCHEDULE**

(14)

### to EC-Type Examination Certificate KEMA 00ATEX1132 X

#### Routine tests

The completed assembly of the load cell shall withstand for one minute, without breakdown, the application of 500 Vac between excitation and output circuits, connected together, and the metal housing.

#### (16) Report

KEMA No. 2007353.

### (17) Special conditions for safe use

If a Load Cell is not connected to certified intrinsically safe circuits, the free end of the permanently connected cable must be connected outside the hazardous area or, when inside the hazardous area, in an enclosure with a suitable type of explosion protection and in accordance with the requirements of the type of protection applied.

For the parameters of the intrinsically safe circuits, refer to the electrical data mentioned at (15).

## (18) Essential Health and Safety Requirements

Essential Hea	alth and Safety Requirements not covered by the standards listed at (9)
Clause	Subject
1.0.5	Marking
1.0.6 b)	Instructions

These Essential Health and Safety Requirements are examined and positively judged. The results are laid down in the report listed at (16).

#### (19) Test documentation

Certificate of Conformity KEMA No. Ex-92.C.6227

KEMA No. Ex-92.C.6585 KEMA No. Ex-92.C.6586 KEMA No. Ex-92.C.6587 KEMA No. Ex-92.C.6588 KEMA No. Ex-94.D.9274 KEMA No. Ex-94.C.8398 KEMA No. Ex-99.E.7228



# (13) SCHEDULE

# (14) to EC-Type Examination Certificate KEMA 00ATEX1132 X

# Test documentation (continued)

657		10. A 10		dated
2.	Description M		)	
	Description M		)	
		lodel CSP-M and Model CP-M	(	
	Description M Description M		(	06.12.2001
	Description M			00.12.2001
	Description M		΄.	
	Description M		í	
		lodel 5103/9103	í	
3.	Drawing No.	E-401009, rev. A (sheet 1)		24.10.2001
	-LL	E-401009, rev. A (sheet 3)		25.10.2001
		899409, rev. A (2 sheets)		14.11.1996
		E-404001, rev. A (2 sheets)		26.10.2001
		E-404002, rev. A (4 sheets)		29.10.2001
		E-606361		30.10.2001
		E-606362		30.10.2001
		E-403001, rev. B (sheet 1)		01.11.2001
		E-403001 (sheet 2)		02.11.2001
		899446 (2 sheets)		14.11.1996
		E-405001, rev. A (sheet 1)		02.11.2001
		E-405001 (sheet 2) 899100		06.11.2001 20.09.1994
		E-402001, rev. A (sheet 1)		06.11.2001
		E-402001 (sheet 2)		06.11.2001
		600845		26.11.2001
		899180, rev. A (sheets 1 and 2)		07.11.2001
		899180 (sheets 3 and 4)		08.11.2001
		899175, rev. A (2 sheets)		20.11.2001
		899120, rev. A (sheet 1)		06.11.2001
		899120, rev. A (sheet 2)		07.11.2001
		899120 (sheet 3)		07.11.2001
		899115, rev. A (2 sheets)		21.11.2001
		899054 (sheets 1, 3, 4, 5 and 6)		16.11.2001
		899054 (sheet 2)		14.11.2001
		899049, rev. B (3 sheets)		19.11.2001
		899052, rev. A (sheets 1 and 3)		21.11.2001
		899052, rev. B (sheet 2)		21.11.2001
		899021, rev. A		21.11.2001
		899608 (sheet 1)		05.03.2001
		899608 (sheet 2)		23.11.2001
		E-490001, rev. A		29.01.2001
		E-490002, rev. A		30.01.2001
		E-490013		11.04.2001
		899044, rev. D (2 sheets)		23.02.2001
		899047, rev. B		01.05.2001

# 4. Samples



# **AMENDMENT 1**

# to EC-Type Examination Certificate KEMA 00ATEX1132 X

Manufacturer: Vishay Revere Transducers Europe B.V.

Address: Ramshoorn 7, 4824 AG Breda, The Netherlands

#### Description

In future, the Load Cells Model CSP-M-...-.. and Model CP-M-...-.. may also be constructed in accordance with the documentation listed below.

In future, the Load cells may also be used with the electrical data stated below.

In future, the Load cells may also be used in areas in which explosive atmospheres caused by air/dust mixtures are present continuously, for long periods or frequently.

#### Marking

The marking of the equipment shall include the following:

The maximum surface temperature of the enclosure T = 70 °C is based on a maximum ambient temperature of 40 °C. The temperature is determined for a dust layer with a thickness of maximum 5 mm.

#### Electrical data

#### Model HCB and Model 9102

Excitation circuit(green and black wires)	in type of explosion protection intrinsic safety EEx ia IIC.
Signal output circuit(white and red wires)	in type of explosion protection intrinsic safety EEx ia IIC.
Sense output circuit (optional) (yellow and blue wires)	in type of explosion protection intrinsic safety EEx ia IIC.

The excitation circuit, the signal output circuit and the optional sense output circuit are galvanically connected and may only be connected to certified intrinsically safe circuits. Voltage, current and power addition of the circuits must be taken into account.

The total maximum values for the above mentioned circuits are:

For longer cables than specified in the description, the capacitance and inductance of the additional cable must be taken into account.



# **AMENDMENT 1**

# to EC-Type Examination Certificate KEMA 00ATEX1132 X

#### Electrical data (continued)

Model SHBxR, Model BSP, Model CSP-M, Model CP-M, Model HPS, Model SSB, Model RLC, Model 5103 and Model 9103

Excitation circuit	in type of explosion protection intrinsic safety EEx ib IIC.
Signal output circuit	in type of explosion protection intrinsic safety EEx ib IIC.
Sense output circuit (optional)(yellow and blue wires)	in type of explosion protection intrinsic safety EEx ib IIC.

The excitation circuit, the signal output circuit and the optional sense output circuit are galvanically connected and may only be connected to certified intrinsically safe circuits. Voltage, current and power addition of the circuits must be taken into account.

The circuits of Model CSP-M and Model CP-M shall be considered to be connected to earth.

The total maximum values for the above mentioned circuits, with exception of the circuits of Model RLC, for loads of 60 kg, 130 kg, 28 t and 60 t, are:

For Model RLC, for loads of 60 kg, 130 kg, 28 t and 60 t, the maximum values for the above mentioned circuits are:

For longer cables than specified in the description, the capacitance and inductance of the additional cable must be taken into account.

# **KEMA**

# **AMENDMENT 1**

# to EC-Type Examination Certificate KEMA 00ATEX1132 X

### Routine tests

For Model CSP-M and Model CP-M a routine test is not applicable.

All other data remain unchanged.

### **Test documentation**

		dated
Drawing No.	899608 Sheet 1 of 2, rev. A	21.01.2005
	899120 Sheet 1 of 3, rev. B	23.02.2005
	899120 Sheet 2 of 3, rev. B	23.02.2005
	E-402001 Sheet 1 of 2, rev. A	06.11.2001
	E-405001 Sheet 1 of 2, rev. B	01.02.2005
	E-403001 Sheet 1 of 2, rev. D	13.07.2005
	E-404002 Sheet 1 of 4, rev. B	26.01.2005
	E-404002 Sheet 2 of 4, rev. B	26.01.2005
	E-404001 Sheet 1 of 2, rev. B	26.01.2005
	E-490015 Sheet 2 of 8, rev. B	12.07.2005
	E-490015 Sheet 7 of 8, rev. B	16.11.2005

Armem, 12 January 2006 KEMA Quality B.V.

C.G van Es

Certification Manager